



Addendum # 5

To: All bidders; **Fire Station 2 Demolition and New Construction**
From: Tracy Owens, Purchasing Agent
CC: Chief Waring
Chief Allston
Lisa Wallace

Date: July 13, 2015
Re: Bid related Information

Message:

This Addendum No. 5 modifies the solicitation only in the manner and to the extent as stated herein.

Q1. Would you please clarify what type of door you would like for the front entrance, under the canopy (door #11)?

A1. A 3070 full vision glass, aluminum framed storefront door, -- or --- a 3070 insulated metal door, with a half vision glass, and hollow metal frame.

Respondent shall acknowledge receipt of this addendum by completing this section and returning it with the Bid Submittal. Failure to acknowledge this addendum may be cause for rejection.

Name of Company

Contractor Signature

Thank you,
Tracy Owens
Town of Summerville, Purchasing Agent